



**IDAHO
POWER**

An IDACORP Company

IDAHO POWER COMPANY
P.O. BOX 70
BOISE, IDAHO 83704

16 September 2004

Mr. Kip W. Runyan, P.E.
2233 Spring Mountain Drive
Boise, ID 83702
Ph 208-384-0960
Fax 208-384-5978
<mailto:KRunyan50@aol.com>

EX. G

RE: Arrowrock Dam Hydroelectric Project

Dear Mr. Runyan:

This letter is to inform you of the progress of your generation interconnection request:

Date of request	Location	Amount (MW)	Requested interconnect date
8/16/04	Elmore County	1.5 MW	May 1, 2007

The Feasibility Study indicates that our system is capable of integrating your generation project at the specified location. These results are based upon studies performed to date, and upon your application indicating synchronous machines will be utilized. At this time, a System Impact Study is not required.

Interconnection facilities, including metering and protection equipment, will be required. This equipment which will be owned by Idaho Power Company typically can be expected to cost approximately \$100,000. However, that design and cost detail will be determined as part of the Facilities Study, used to prepare actual construction work orders. We also understand you will be constructing and providing other facilities to reach Idaho Power's existing distribution line and other requirements associated with the interconnection.

Your project will be forwarded on to John Barrutia who will assist you through the Facility Study process. We will be offering a study agreement to proceed with that work shortly.

If you have any questions please do not hesitate to contact either myself or John Barrutia (388-2222).

Sincerely,

"Kip" David L. Sikes, P.E.
Planning Leader
Idaho Power Company
dsikes@idahopower.com
(208) 388-2459

cc: John Barrutia/IPC
Rowena Bishop/IPC